# SIEMENS



2-port valves MVI421.15 to MVI421.25



3-port valves MXI421.15 to MXI421.25



## 2-Port and 3-Port Zone Valves, PN16

MVI421... MXI421...

- Operating voltage AC 230 V, 2-position control signal
- Spring return
- Positioning force 105 N
- · Direct mounting with union nut, no tools required
- · Ergonomically designed manual adjuster
- Auxiliary switch, type ASC2.1/18 (optional)
- Hot-pressed brass valve body
- DN15, DN20 and DN25
- k<sub>vs</sub> = 2 ... 5m<sup>3</sup>/h
- Internally threaded connections Rp... to ISO 7/1

#### Use

- In ventilation and air conditioning systems for water-side terminal unit control in closed circuits, e.g. induction units, fan coil units, small re-heaters and small re-coolers, for use in
  - -2-pipe systems with 1 heat exchanger for heating and cooling
  - -4-pipe systems with 2 separate heat exchangers for heating and cooling
- In closed-circuit zone heating systems, e.g.
  - -Separate floors in a building
  - -Apartments
  - -Individual rooms
  - -Floor heating

#### Type summary

	DN Co	onnection	k <sub>vs</sub>	MVI421	Δps	MXI421	Δp <sub>max</sub>	Actuator Positioning force
			[m <sup>3</sup> /h]	(2-port)	[kPa]	(5-рон)	[kPa]	r ositioning force
	15	Rp ½"	2.0	MVI421.15	300	MXI421.15	300 <sup>1)</sup>	105 N
	20	Rp ¾"	3.5	MVI421.20	300	MXI421.20		
	25	Rp 1"	5.0	MVI421.25	300	MXI421.25		
Accessories Thermostats	$k_{vs} = N$ $\Delta p_s = N$ $a$ $\Delta p_{max} = N$ $a$ $1)$ $3$ $1$ $F$ Type code ASC2.1/18 Type code RAB	lominal flow ressure of 10 faximum per cutating rang 00 kPa wher 00 kPa wher 00 kPa wher or quiet serv <b>e Desig</b> <b>3</b> Auxilia <b>e Therm</b> RAB10	rate of col 20 kPa (1) missible d ge of the m n used for n used for n used for ry switch con ostat con p; RAB10	d water (5 to 3 bar) ifferential pres oose off pressu ifferential pres notorized valve diverting applica commended r son / off A patible to MV 1; RAB20; RAE	0 °C) throu sure at whi re) sure acros cations tions tot to excee witching p t approx. 5 //1421 / M 320.1; RAE	igh the fully op ich the motori is the valve's of ed 100 kPa di point 0 % stroke IXI421 330; RAB30.1	pen valve (H zed valve wil control path, fferential pre Contact Max. AC RAB40.1	L 100), by a differential I close securely valid for the entire ssure rating 2 250 V, 3 (2) A
	RCC	RCC10	); RCC20;	RCC20.1; RC	C30			
	RDF	RDF10	; RDF10. <sup>-</sup>	1; RDF10.2; R	DF20; RDF	30		
Delivery Function	The valve separate.	es and actu	ators are	e packed tog	jether, th	e auxiliary s	witches wi	ll be packed
	The zone required t deviates f actuators set point f If required	valves are to drive the from the se , causing the causing the control d the MI4	e closed v motorise et point, t ne valve signal is 21 val	when de-ene ed valve act he controller to open. Wh cut off and ve can be a	ergised. A uators. If r delivers nen the te the valve dded with	An on/off co the tempera a control si emperature closes. a an auxiliar	ntroller (the ature of the gnal that d of the med y switch A	ermostat) is e medium rives the ium reaches the SC2.1/18.
Accessoires								
ASC2.1/18 auxiliary switch	The optio with two s It switche 0 50 %	nal auxiliar screws. s at a stroł o : Q11 →	ry switch ke of app → Q12 clo	can be fitted prox. 50 %. psed Q11	d to the a → Q14 o	ctuator		
	50 % 1	I: Q11 →	→ Q12 op	en Q11	ightarrowQ14 c	losed		
	See «Tec	hnical data	a» for fur	ther informa	tion on th	e auxiliary	switch.	-

2/8

2



- = Differential pressure across the fully openend valve and the valve's control path A  $\rightarrow$  AB (2- $\Delta p_{v100}$ port valves), AB  $\rightarrow$  A (3-port diverting valves) or A  $\rightarrow$  AB (3-port mixing valves) by a volume flow V 100
- = Volume flow through the fully open valve  $(H_{100})$ . V 100
- = Maximum permissible differential pressure across the valve's control path, valid for the  $\Delta p_{max}$ entire actuating range of the motorised valve (300 kPa for diverting applications, 100 kPa for mixing applications)
- 100 kPa = 1 bar  $\approx$  10 mWG
- $1 \text{ m}^{3}/\text{h} = 0.278 \text{ l/s water at } 20 ^{\circ}\text{C}$

See also «Mounting notes» and «Commissioning notes».

The valves should preferably be installed in the return, where the seals are exposed to lower temperatures. It is not allowed to put a shut off at the bypass port B.

Recommendation A strainer should be fitted upstream of the valve. This increases reliability.

Valve construction	Valve series	Valve flow in control mode		Valve stem		
		Inlet A	Outlet AB	Retracted	Extended	
2-port valves	VV46					
	АМАВ	Variable	Variable	A → AB closes	A → AB opens	

Warning The direction of flow MUST be as indicated by the arrow, from  $A \rightarrow AB$ .

Valve construction	Valve series	Valve flow in control mode			Valve stem	
		AB	Α	В	Retracted	Extended
3-port diverting valves	VX46 AB	Inlet: constant	Outlet: variable	Outlet: variable	AB → A closes AB → B opens	AB → A opens AB → B closes
3-port mixing valves	VX46 AB A B	Outlet: constant	Inlet: variable	Inlet: variable	AB A closes AB B opens	AB A opens AB B B closes

Warning

The direction of flow MUST be as indicated by the arrow, from  $AB \rightarrow A$  and  $AB \rightarrow B$  (diverting valves) or  $A \rightarrow AB$  and  $B \rightarrow AB$  (mixing valves).

#### Mounting notes

Orientation



In addition, the direction of flow as described under «Engineering notes» must be observed.

*Mounting*Assembly is made with the coupling nut; no adjustments are required.

The actuator must be fitted in position 1 (also refer to « Manual operation »):

- Position the actuator and tighten the coupling nut manually •
- Do not use any tools such as wrenches

### Suitable conduit shall connected to the actuator when undergone the wiring work of the product. Manual operation Turn switch with approximately 90 % valve stroke latch Open valve manually 4867Z09 а 4867Z08 b Release switch Switch up to the impact turn and release 4867Z11 manually 4867Z10 Ð Ð ΠΠ **Commissioning notes** Manual adjustment Through operation of the manual adjuster or removed the actuator, the through-port $AB \rightarrow A$ of the valve can be opened. With the 3-port valves, the bypass port will be closed. The valves will be opened by their own spring (normally open). Warning A Before performing any service work on the valve and/or actuator: Switch OFF the pump and power supply. • • Close the main shut-off valve in the pipework. Release pressure in the pipes and allow them to cool down completely. • If necessary, disconnect electrical connections from the terminals. The valve may be commissioned only with the manual wheel pre-set or with a correctly mounted actuator.

Caution  $\triangle$ 

5/8

The valve and actuator do not require maintenance Faulty actuators can be replaced without removing the valve from the pipework. The actuator cannot be repaired.

Replacement actuator



Replacement actuators (AC 230 V versions) can be ordered by quoting type code : SFA21

#### Disposal



The valve must be dismantled and separated into its various constituent materials before disposal.

The actuator may not be disposed of togetherwith domestic waste.

Legislation may demand special handling of sertain components, or it may be sensible from an ecological point of view.

Current local legislation must be observed.

#### Warranty

The technical data supplied for these values is valid only for values used in conjunction with the actuators SFA... .

Use with third-party actuators invalidates any warranty offered by Siemens Building Technologies / HVAC Products.

#### **Technical data**

Valves					
Operating data	PN class	PN16 to EN1333			
	Valve characteristic	The trim is designed for ON/OFF control only			
	Leakage	According to DIN EN 1349			
	2-port valve:				
	Path A $\rightarrow$ AB	00.05 % of k <sub>vs</sub>			
	3-port valve				
	Path AB $\leftrightarrow$ A	00.05 % of k <sub>vs</sub>			
	Bypass AB $\leftrightarrow$ B	Max. 25 % of k <sub>vs</sub>			
	Admissible media	Chilled water, low-temperature hot water and water			
		with frost protection additives. Recommendation:			
		water should be treated as specified in VDI 2035			
	Temperature of medium	1 110 °C, or max. 120 °C for brief period			
	Admissible operating pressure	1600 kPa (16 bar)			
	Nominal stroke	2.5 mm			
Materials	Valve body	Hot-pressed brass			
	Stem	Stainless steel			
	Plug, seat, gland	Brass or bronze Rg5			
	Stem seal	EPDM O-rings			
Dimensions / Weight	Dimensions and weight	See «Dimensions»			
	Threaded connections (Valve)	Rp to ISO7/1			

Actuators					
Power supply	Rated voltage	AC 230 V			
	Voltage tolerance	–15 / +10 %			
	Rated frequency	50 Hz			
	Max. power consumption	9.8 VA			
	Fuse protection for incoming cable	Max. 3 A (external)			
Control	Control signal	2-position via temperature controller			
		Phase cut and pulse-width-modulated signals are			
		not suitable.			
	Opening/closing operations	Recommended number: approx. 10 000 / year			
		(equivalent to approx. 50 per day)			
Functional data	Position with de-energized actuator				
	2-port valve (MVI421)	$A \rightarrow AB$ closed			
	3-port valve (MXI421)	$AB \leftrightarrow A closed$			
	Running time	30 50 s (opened by motor, closed by spring force)			
	Nominal stroke	2.5 mm			
	Nominal force	105 N			
	Manual adjustment	90 %			
Electrical connection	Lead wire	3-core 0.15 m			
Industry standards	Meets the requirements for CE marking:				
	EMC Directive	89/336/EEC			
	Low Voltage Directive	73/23/EEC			
	Protection class	I to EN 60730, Section 2.7			
	Housing protection standard	IP30 to EN60529			
Dimensions / Weight	Dimensions and weight	See «Dimensions»			
	Weight auxiliary switch	0.150 kg			
	without auxiliary switch	0.585 kg			
	with auxiliary switch	0.692 kg			
Materials	Base-plate	Die-cast aluminum			
	Housing	Polycarbonate			
Housing colors	Base and cover	Light gray, RAL7035			
Auxiliary switch ASC2.1/18	Switch type	Changeover contact			
	Switching point	at approx. 50 % stroke			
	Switching capacity	AC 250 V/ 3 A resistive, 2 A inductive			
	Connecting cable	3-core, 1.8 m / AWG18 (0.96 mm <sup>2</sup> )			

General ambient conditions		Operation	Transport	Storage
		IEC 721-3-3	IEC 721-3-2	IEC 721-3-2
	Environmental conditions	Class 3K3	Class 2K3	Class 2K3
	Temperature	+1 +50 °C	–25 +70 °C	–5 +50 °C
	Humidity	5 85 %rh	< 95 %rh	5 95 %rh

7/8

